



## GENERAL NOTES

1. DO NOT ATTACH DUCT TO TOP OF LOWER LOUVER BLADE AS TYPICAL. THIS CREATES SEALING PROBLEMS AT MULLIONS AND OTHER VERTICAL MEMBERS.
2. CONSTRUCT SLEEVE AND DUCTWORK TO SUPPORT WEIGHT OF SERVICE TECHNICIAN.
3. SEAL JOINT BETWEEN DUCT AND SLEEVE WATER TIGHT ALL AROUND.
4. INSULATE DUCT AND SLEEVE AS SPECIFIED.

### NOTE TO A/E:

1. INDICATE WORK TO BE DONE BY GENERAL CONTRACTOR AND VENT CONTRACTOR.
2. OUTSIDE AIR PLENUM IS PREFERRED. SEE OUTSIDE AIR PLENUM CONSTRUCTION DETAIL.

1

A1.01

## WALL LOUVER DETAIL

SCALE: NO SCALE

Detail Title:	Detail No.: 23 37 00 - 01	Facilities Planning & Construction Standard Detail	UNIVERSITY OF <b>Nebraska</b> Lincoln
WALL LOUVER DETAIL	Scale: N.T.S.		
	Date: JULY 2014		